

MANDURAH

PO Box 2215
MANDURAH WA 6210
Tel: (08) 9535 5833
Email: admin@besurveys.com.au

BUNBURY

PO Box 1148
BUNBURY WA 6230
Website: www.besurveys.com.au

Date: 27-05-2026

Attention: Adam Riley
SRG Global

SURVEY RESULTS

COV-TEN-CON 514 stack raise works

TOWER 1 Module 1 top of column RL

Method.


Locale control points used to establish RL of instrument (Leica MS50 +/-1mm)

Example PC01 SM002 (E:240.625 N:315.031 RL:5.900)

Values written on plates in concrete.

Prism held on top flange and RL recorded.

Col 1
20.002mRL
+2mm



Col 3
19.997RL
-3mm

Col 2
20.004mRL
+4mm

Design RL = 20.000mRL
C14-005-100-MPD-102

Chris John
BE SURVEYS

ISOMETRIC VIEW
NTS